

P R E V I E W

Interim Simulation Result

*****NOT FOR RATING**

Run: Base

NOT FOR RATING		PROJECT DETAILS	NOT FOR RATING
Project Name: Monika Lobe House		File Name: Monika Lobe House for Glazi	
Postcode: 7015		Climate Zone: 26	
Design Option: Base Design			
Description: Thermal calculation to architectural construction plans prepared by , Detlev Geard, Architect, Proje			

NOT FOR RATING		Client Details	NOT FOR RATING
Client Name: Monika Lobe			
Phone: 0421992664	Fax:	Email: berlinmoni@gmx.de	
Postal Address: 11a Kurrewa Court Bellerive Tasmania			
Site Address: 8b Fig Place, Tasmania 7015, TAS		Exposure: Suburban	
Council submitted to (if known by assessor): Clarence Council			

NOT FOR RATING		Assessor Details	NOT FOR RATING
Assessor Name: Dr Detlev Geard		Assessor No.	
Phone: 0362349008	Fax:	Email: dageard@bigpond.net.au	
Project Code: AC 122	Assessment Date: 12/07/2019	Time: 13:22:09	
Assessor Signature:			

CALCULATED ENERGY REQUIREMENTS*				
Heating	Cooling (sensible)	Cooling (latent)	Total Energy	Units
21.4	3.4	0.2	25.0	MJ/m ² .annum
* These energy requirements have been calculated using a standard set of occupant behaviours and so do not necessarily represent the usage pattern or lifestyle of the intended occupants. They should be used solely for the purposes of rating the building. They should not be used to infer actual energy consumption or running costs. The settings used for the simulation are shown in the building data report.				

AREA-ADJUSTED ENERGY REQUIREMENTS				
Heating	Cooling (sensible)	Cooling (latent)	Total Energy	Units
18.1	2.9	0.2	21.1	MJ/m ² .annum
Floor area	conditioned:	109.8 m ²	unconditioned:	98.7 m ² garage: 47.9 m ²

BAND RESULT
9.3

Area-adjusted band score thresholds									
Band 1	Band 2	Band 3	Band 4	Band 5	Band 6	Band 7	Band 8	Band 9	Band 10
723	498	354	262	202	155	113	71	31	0